

Executive Summary

Objective To determine the fire performance of a cable retaining clip, using the principles of BS 5839-1: 2013 Section 26.2 e)



Generic Description	Product reference	Thickness	Weight
Coated steel cable retaining clip	'EFC25 Ext Conduit Clip'	1.2mm	Not stated
Epoxy Coating	'Powder coating white'	40-60microns	Not stated
Metallic Conduit Clip	'EFC25 Ext Conduit Clip'	1.2mm	171g per 100pcs
Please see pages 6 & 7 of this test report for the full description of the product tested			

Test Sponsor Deligo Limited, Unit 17 Blackbrook Valley Indest, Narrowboat Way, Dudley, West Midlands. DY2 0XQ

Test Results: When tested using the general principles of BS 5839-1 Section 26.2 e), the cable retaining clip maintained its integrity for the duration of the tests.

Date of Test 11th & 12th April 2018

Signatories

	
Responsible Officer I. White * Testing Officer	Authorised T. Mort * Senior Technical Officer

* For and on behalf of Exova Warringtonfire.

Report Issued: 22nd May 2018

This version of the report has been produced from a pdf format electronic file that has been provided by Exova Warringtonfire to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Exova Warringtonfire.

Document No.: 397612
 Author: I. White
 Client: Deligo Limited

Page No.: 2 of 10
 Issue Date: 22nd May 2018
 Issue No.: 1