

Executive Summary

Objective To determine the fire performance of a (product), using the principles of BS 5839-1: 2017 Section 26.2 e)


Generic Description	Product reference	Thickness	Weight per unit area
Mild steel cable clip	"TFC38-50"	0.7mm	890g per 100 pcs
Please see pages 6 & 7 of this test report for the full description of the product tested			


Test Sponsor Deligo Ltd., Unit 17 Narrow Boat Way, Dudley. DY2 0XQ

Test Results: When tested using the general principles of BS 5839-1:2017 Section 26.2 e), the cable supported by the steel cable clip maintained its integrity for the duration of the tests.

Date of Test 30th August and 5th September 2018

Signatories


 Responsible Officer
 I. White *
 Testing Officer


 Authorised
 S. Deeming *
 Business Unit Head

* For and on behalf of Exova Warringtonfire.

Report Issued: 24th September 2018

This version of the report has been produced from a pdf format electronic file that has been provided by Exova Warringtonfire to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Exova Warringtonfire.